

REF: GDC/MS/SC/005/18-19/dk

16th January 2019

TO: ALL BIDDERS

Dear Sir/Madam,

ADDENDUM 2: CLARIFICATION

RE: TENDER FOR SUPPLY & DELIVERY OF STORES CONSTRUCTION MATERIALS TO BARINGO – SILALI GEOTHERMAL PROJECT (RESERVED FOR YOUTH & WOMEN) - TENDER REF: GDC/SC/OT/017/2018:2019

Pursuant to clause 2.5 of the tender document and in response to bidder's request for clarifications, GDC wishes to provide the following clarifications;

No.	Bidders Query	GDC Response
1.	The gauge of Damp Proof Membrane (Item number 9 for sub structure)	Damp Proof Membrane shall be Gauge 1000 sheet
2.	The gauge of Rain water down pipe (Item number 8 for roofing)	All rain water down pipe shall be iron sheet gauge 28 or PVC class C

All other instructions and closing date remain unchanged.

Yours faithfully,



DORIS KYAKA
MANAGER, SUPPLY CHAIN
FOR: GEOTHERMAL DEVELOPMENT COMPANY