

17th July 2024

REF: GDC/MSC/005/24-25/IM

TO: ALL BIDDERS

Dear Sir,

ADDENDUM 1 – CLARIFICATION

RE: TENDER FOR PROVISION OF UPGRADE AND MAINTENANCE WORKS FOR MENENGAI PUMP HOUSE SUBSTATION– TENDER REFERENCE No. GDC/INFRA/OT/071/2023-2024.

In response to bidder's request for clarification, GDC wishes to provide the following response;

No.	Bidder's Request	GDC Response
1.	We seek clarification on the following specifications: There are some technical discrepancies on the technical specifications: Page 51-52 states the following for Incomer, Feeder1&2, 1. Rated short-circuit breaking current - up to 40KA. 2. Rated continuous current of feeders - up to 3150A.	GDC wishes to clarify as below; 1. Rated short-circuit breaking current up to 40 kA for 3sec. 2. Rated continuous current of feeders - SF6 Up to 3150 A.
2.	Request for extension of time for submission.	The tender closing date has been extended from Thursday 18th July 2024 to Thursday 25th July 2024 .

NB: All other requirements/instructions remain unchanged.

Yours faithfully,



PATRICK KAPTO
Ag. MANAGER, SUPPLY CHAIN
FOR: GEOTHERMAL DEVELOPMENT COMPANY