

2<sup>nd</sup> November 2023

REF: GDC/MS/005/23-24/dk-flk

TO: ALL BIDDERS

Dear Sir,

**ADDENDUM 2: CLARIFICATION**

**RE: RE: TENDER FOR THE SUPPLY AND DELIVERY OF SOLAR FLOOD LIGHTING SYSTEM FOR BARINGO-SILALI GEOTHERMAL FIELD (RESERVED FOR YOUTH'S ONLY) - GDC/DEM/OT/025/2023:2024.**

In response to bidder's request for clarification, GDC wishes to provide the following response;

S.N	BIDDER'S REQUEST	GDC'S RESPONSE
1.	What comes on top of each pole? <i>A technical diagram for the solar flood light stand has been attached as an annex</i>	One side – Solar panel Other side – Solar Flood light
2.	Must the poles only be galvanized or a certain color.	Undercoat – Primer Top coat – Two coats of Aluminium Paint

NB: All other instructions remain unchanged.

Yours faithfully,



**DORIS KYAKA**  
**MANAGER, SUPPLY CHAIN**  
**FOR: GEOTHERMAL DEVELOPMENT COMPANY**