

22nd June, 2022.


To: All Bidders

Dear Sir/Madam,

ADDENDUM TWO (2) - CLARIFICATION

RE: TENDER FOR SUPPLY OF WIRE ROPES AND LIFTING TOOLS FOR BARINGO SILALI GEOTHERMAL PROJECT - TENDER NO: GDC/DPL/OT/052/2021-2022


In response to bidder's request for clarification, GDC wishes to clarify as follows.

No.	Bidder's Query	GDC Response
1.	As for item 18-23, according to standard EN1492-1, it is polyester webbing sling with eyes, but the picture is polyester round sling standard EN1492-2 Please advise us the correct standard EN1491-1 or EN1492-1	Correct standard to be referenced is EN1492-1 EN1492-1 has below picture as a guide; 
2.	Schedule one (1) wire ropes and lifting tools: Q) About the wire rope steel material, which type is required 1. Hot dipped galvanized carbon steel or 2. Electro galvanized carbon steel	The required wire rope material is: Hot dipped galvanized carbon
3.	Closing Date for the Tender is June 27 th . However, this is a short period of time for us and our suppliers to provide all the items required for us to be considered responsive. Therefore, requesting for one-week extension.	The tender closing date is hereby extended from 27 th June 2022 to 5th July 2022 at 2:00PM
4.	Foreign Currency is not allowed for this tender. Our suppliers can only quote with foreign currencies: USD or AED. Requesting if we can be allowed to provide a quote with a foreign currency.	No. Foreign currencies are not allowed as stated in ITT clause 14.2 of the Tender Data Sheet (TDS). Tenderers to express and quote their prices in Kenya Shillings (Kshs) only.



All other instructions/requirements remain unchanged.

Yours faithfully,



DORIS KYAKA
MANAGER, SUPPLY CHAIN